

Textilní zkušební ústav

TEXTILNÍ ZKUŠEBNÍ ÚSTAV, s.p.

(TEXTILE TESTING INSTITUTE)
CERTIFICATION BODY FOR THE CERTIFICATION OF PRODUCTS
VÁCLAVSKÁ 6, 658 41 BRNO, CZECH REPUBLIC

issues

to the producer: GAPA MB, s.r.o., Svatovítská 217, Mladá Boleslav III, Czech Republic

IN: 40767795

TESTIMONIAL

No.: 17 - 015

this Testimonial confirms that the product:

Cleaning entrance matting system TOPWELL with textile inserts

made of aluminium with textile floor covering in the form of strip material composition cut pile: 100% polyamide; backing PC

complies with the requirements of the standard:

• EN 13501-1+A1:2010 Fire classification of construction products and building elements – Part 1: Classification using test data from reaction to fire tests (Art. 9.2, 9.4, 12.6, 12.9.2, Table 2)

Testing was carried out according to the standards:

- EN ISO 11925-2 Reaction to fire tests Ignitability of building products subjected to direct impingement of flame Part 2: Single-flame source test
- EN ISO 9239-1 Reaction to fire tests for floorings Part 1: Determination of the burning behaviour using a radiant heat source

Table: Evaluated parameters and classification

Testing method	Parameter	Requirement class B _{fl} - s1	Value identified	Evalua- tion
EN ISO 11925-2 exposure – 15 s	Flame spread Fs	art. 12.6 $F_S \le 150 \text{ mm do } 20 \text{ s}$	Flame didn't spread more than 150 mm	S
EN ISO 9239-1	Critical flux (kW.m ⁻²)	art. 12.6 ≥ 8 kW.m ⁻²	CHF 11,3	S
	Smoke (%.minute)	art. 12.9.2 ≤ 750 % . minute	40,8	S

Legend: S - Satisfy

Classification according to the reaction to fire: $B_{fl} - s1$

This Testimonial has been issued on the basis of the application No. COV/17/039 from 11.01.2017. The base for this Testimonial is the Test Protocol No. AZL 17/0091 from 10.02.2017, issued by the accredited testing laboratory of $TZ\dot{U}$ Brno. Test conditions are specified in the Test Protocol.

Testimonial was issued: Brno, 14.02.2017

Validity up to: 28.02.2019

Issued by:

Jitka Paulová Certification Department