TEXTILNÍ ZKUŠEBNÍ ÚSTAV, s.p.
(TEXTILE TESTING INSTITUTE)
CERTIFICATION BODY FOR THE CERTIFICATION OF PRODUCTS
CEJL 480/12, ZÁBRDOVICE, 602 00 BRNO, CZECH REPUBLIC

issues

to the client: **GAPA MB, s.r.o., Svatovítská 217, 293 01 Mladá Boleslav III, Czech Republic**
ID: 40767795

TESTIMONIAL

No.: 26 – 055

this Testimonial confirms that the product:

Cleaning entrance matting system LAWEL with textile inserts

made of aluminium with textile floor covering in the form of strip
material composition: pile – 100 % polyamide, backing PVC;
height: 14 mm; mass per unit area (textile): 11 kg/m^2

complies with the requirements of the standard:

- **EN 13501-1:2018 Fire classification of construction products and building elements – Part 1: Classification using test data from reaction to fire tests (art. 9.2, 9.4, 12.6, 12.9.2, Table 2)**

  Testing was carried out according to the standards:
  - **EN ISO 11925-2** Reaction to fire tests – Ignitability of building products subjected to direct impingement of flame – Part 2: Single-flame source test
  - **EN ISO 9239-1** Reaction to fire tests for floorings – Part 1: Determination of the burning behaviour using a radiant heat source

Table: Evaluated parameters and classification

Testing method	Parameter	Requirement **class B_{fl} – s1**	Value identified	Evaluation
EN ISO 11925-2 exposure – 15 s	Flame spread F_S	art. 12.6 $F_S \leq 150$ mm do 20 s	**Flame didn't spread more than 150 mm**	**S**
EN ISO 9239-1	Critical heat flux CF (kW.m^{-2})	art. 12.6 ≥ 8.0 kW.m^{-2}	**≥ 11**	**S**
	Smoke (%.minute)	art. 12.9.2 ≤ 750 % . minute	**10.6**	**S**

Legend: S - Satisfy

Classification according to the reaction to fire: B_{fl} – s1

This Testimonial has been issued on the basis of the application No. COV/26/228 of 12.06.2026. The base for this Testimonial are the Test reports No. AZL 17/0091 of 10.02.2017, No. AZL 26/0744 of 10.07.2026, issued by the accredited testing laboratory of TZÚ Brno. Test conditions are specified in the Test reports.

Testimonial was issued: Brno, 14.08.2026
Validity up to: 31.08.2028

Issued by:

Tomkovej
Lenka Tomková
Certification Body

CERTIFIKAČNÍ ORGÁN PRO CERTIFIKACI VÝROBKŮ * BRNO *