TEXTILNÍ ZKUŠEBNÍ ÚSTAV, s.p.
(TEXTILE TESTING INSTITUTE)
CERTIFICATION BODY FOR THE CERTIFICATION OF PRODUCTS
CEJL 480/12, ZÁBRDOVICE 602 00 BRNO, CZECH REPUBLIC

issues

to the manufacturer: **Fatra, a.s., třída Tomáše Bati 1541, 763 61 Napajedla, Czech Republic**
ID: 27465021

TESTIMONIAL

No.: 25 – 048

this Testimonial confirms that the product:

Cleaning entrance matting system TOPWELL, OPENWELL, LAWELL - type 1877

made of aluminium with PVC profiles

complies with the requirements of the standard:

- **EN 13501-1:2018 Fire classification of construction products and building elements – Part 1: Classification using test data from reaction to fire tests (art. 9.2, 9.4, 12.6, 12.9.2, Table 2)**

  Testing was carried out according to the standards:
  - **EN ISO 11925-2** Reaction to fire tests – Ignitability of building products subjected to direct impingement of flame – Part 2: Single-flame source test
  - **EN ISO 9239-1** Reaction to fire tests for floorings – Part 1: Determination of the burning behaviour using a radiant heat source

Table: Evaluated parameters and classification

Testing method	Parameter	Requirement **class B_{fl} – s1**	Value identified	Evaluation
EN ISO 11925-2 exposure – 15 s	Flame spread F_S	art. 12.6 $F_S \leq 150$ mm do 20 s	**Flame didn't spread more than 150 mm**	**S**
EN ISO 9239-1	Critical heat flux CF ($kW.m^{-2}$)	art. 12.6 ≥ 8 $kW.m^{-2}$	**≥11**	**S**
	Smoke (%.minute)	art. 12.9.2 ≤ 750 % . minute	**107**	**S**

Legend: S - Satisfy

Classification according to the reaction to fire: B_{fl} – s1

This Testimonial has been issued on the basis of the application No. COV/25/126 dated 03/04/2025 and No. COV/26/324 dated 10/09/2026. The base for this Testimonial are the Test Protocols No. AZL 17/0098 dated 10/02/2017, No. AZL 21/0322 dated 24/03/2021, No. AZL 25/0460 dated 29/04/2025, issued by the accredited testing laboratory of TZÚ Brno. Test conditions are specified in the Test report.

Testimonial was issued: Brno, 27.05.2025
Validity up to: 31.05.2027
Update: 13.10.2026

Issued by:

Lenka Tomková
Certification Department

CERTIFIKAČNÍ ORGÁN PRO CERTIFIKACI VÝROBKŮ * BRNO *