



TEXTILNÍ ZKUŠEBNÍ ÚSTAV, s.p.
(TEXTILE TESTING INSTITUTE)
CERTIFICATION BODY FOR THE CERTIFICATION OF PRODUCTS
CEJL 480/12, ZÁBRDOVICE 602 00 BRNO, CZECH REPUBLIC

issues

to the manufacturer: **Fatra, a.s., třída Tomáše Bati 1541, 763 61 Napajedla, Czech Republic**
ID: 27465021

TESTIMONIAL

No.: 25 – 048

this Testimonial confirms that the product:

Cleaning entrance matting system TOPWELL and OPENWELL - type 1877
made of aluminium with PVC profiles

complies with the requirements of the standard:

- **EN 13501-1:2018 Fire classification of construction products and building elements – Part 1: Classification using test data from reaction to fire tests (art. 9.2, 9.4, 12.6, 12.9.2, Table 2)**

Testing was carried out according to the standards:

- **EN ISO 11925-2** Reaction to fire tests – Ignitability of building products subjected to direct impingement of flame – Part 2: Single-flame source test
- **EN ISO 9239-1** Reaction to fire tests for floorings – Part 1: Determination of the burning behaviour using a radiant heat source

Table: Evaluated parameters and classification

| Testing method | Parameter | Requirement class B_n – s1 | Value identified | Evaluation |
|--------------------------------|---|--|---|------------|
| EN ISO 11925-2 exposure – 15 s | Flame spread F _s | art. 12.6 F _s ≤ 150 mm do 20 s | Flame didn't spread more than 150 mm | S |
| EN ISO 9239-1 | Critical heat flux CF (kW.m ⁻²) | art. 12.6 ≥ 8 kW.m ⁻² | ≥11 | S |
| | Smoke (%.minute) | art. 12.9.2 ≤ 750 % . minute | 107 | S |

Legend: S - Satisfy

Classification according to the reaction to fire: **B_n – s1**

This Testimonial has been issued on the basis of the application No. COV/25/126 of 03.04.2025. The base for this Testimonial are the Test Protocols No. AZL 17/0098 of 10.02.2017, No. AZL 21/0322 of 24.03.2021, No. AZL 25/0460 of 29.04.2025, issued by the accredited testing laboratory of TZU Brno. Test conditions are specified in the Test Protocol.

Testimonial was issued: Brno, 27.05.2025
Validity up to 31.05.2027

Issued by:

Tomkova!
Lenka Tomková
Certification Department

