



TEXTILNÍ ZKUŠEBNÍ ÚSTAV, s.p.  
(TEXTILE TESTING INSTITUTE)  
CERTIFICATION BODY FOR THE CERTIFICATION OF PRODUCTS  
CEJL 480/12, ZÁBRDOVICE, 602 00 BRNO, CZECH REPUBLIC

issues

to the client: **GAPA MB, s.r.o., Svatovítská 217, 293 01 Mladá Boleslav III, Czech Republic**  
ID: 40767795

## TESTIMONIAL

No.: 25 – 038

this Testimonial confirms that the product:

### Cleaning entrance mat Victoria

textile floor covering

material composition: cut pile - 100 % polyamide; backing – polyvinylchloride

total thickness: 9,0 mm; total mass: 3 700 g.m<sup>2</sup>

complies with the requirements of the standard:

- **EN 13501-1:2018 Fire classification of construction products and building elements – Part 1: Classification using test data from reaction to fire tests (Art. 9.2, 9.4, 12.6, 12.9.2, Table 2)**  
Testing was carried out according to the standards:
  - **EN ISO 11925-2** Reaction to fire tests – Ignitability of building products subjected to direct impingement of flame – Part 2: Single-flame source test
  - **EN ISO 9239-1** Reaction to fire tests for floorings – Part 1: Determination of the burning behaviour using a radiant heat source

Table No. 1: Evaluated parameters and classification

Testing method	Parameter	Requirement class <b>B<sub>n</sub> – s1</b>	Value identified	Evaluation
EN ISO 11925-2 exposure – 15 s	Flame spread F <sub>s</sub>	art. 12.6 F <sub>s</sub> ≤ 150 mm (20 s)	<b>Flame didn't spread more than 150 mm</b>	<b>S</b>
EN ISO 9239-1	Critical flux (kW.m <sup>2</sup> )	art. 12.6 ≥ 8 kW.m <sup>2</sup>	<b>≥ 8,0</b>	<b>S</b>
	Smoke (%.minute)	art. 12.9.2 ≤ 750 % . minute	<b>≤ 750</b>	<b>S</b>

Legend: S - Satisfy

### Classification according to the reaction to fire: **B<sub>n</sub> – s1**

This Testimonial has been issued on the basis of the application No. COV/25/066 of 03.02.2025. The base for this Testimonial is the Certificate No. 0493-CPR-0149 of 13.01.2025, issued by the CENTEXBEL, Gent, Belgium.

Testimonial was issued: Brno: 14.04.2025  
Validity up to: 30.04.2027

Issued by:

*Tomková*  
Ing. Lenka Tomková  
Certification Department

